






OD ECS 040-1
April 2023

Responsible CB



TEST REPORT SUMMARY

Report Number..... :	CN2406HM 001
Date of issue..... :	2024-04-01
Tested by (name, function, signature):	Ken Ou, PE 
Witnessed by (name, function, signature):	N/A
Approved by (name, function, signature):	Mars Yan, Authorizer 
Supervised by (name, function, signature):	N/A
Testing Laboratory..... :	TÜV Rheinland (GuangDong) Co., Ltd.
Address..... :	No. 199 Kezhu Road, GZ Science City, Guangzhou 510663, P.R.China
Testing procedure..... :	<input type="checkbox"/> ENEC <input type="checkbox"/> CCA NTR <input checked="" type="checkbox"/> ENEC based on IEC EE CBTC with number: DE 2-041457
Customer Testing Procedure..... :	<input type="checkbox"/> E-CTF Stage 1 <input type="checkbox"/> E-CTF Stage 2 <input type="checkbox"/> E-CTF Stage 3
Applicant..... :	TIANCHANG FUAN ELECTRONIC CO., LTD.
Address..... :	286 Renmin East Road, Renhe Town, Tianshang City, 239331 Anhui, P.R. China
Manufacturer..... :	TIANCHANG FUAN ELECTRONIC CO., LTD.
Address..... :	286 Renmin East Road, Renhe Town, Tianshang City, 239331 Anhui, P.R. China
Product..... :	Constant Current LED Driver
Model/Type reference..... :	AAB045-C1050
Trademark..... :	 (PAIRUI)
Ratings..... :	I/P: 220-240VAC, 50/60Hz, O/P: Max.44W SELV; Independent; Class II, IP20, ta:50°C, tc:75°C Other information see 'General production information'.
Certification Scheme..... :	<input checked="" type="checkbox"/> ENEC <input type="checkbox"/> CCA <input type="checkbox"/> Other: _____
Standard(s)..... :	EN 61347-2-13:2014+A1:2017 used in conjunction with EN 61347-1:2015+A1:2021 and EN IEC 62384:2020
<input checked="" type="checkbox"/> The text of the a.m. European Standard was approved by CENELEC is equivalent with the corresponding IEC Publication.	
<input type="checkbox"/> The text of the a.m. European Standard was approved by CENELEC with agreed common modifications and is <u>not</u> equivalent with the corresponding IEC Publication. An EU Deviation Addendum has to be issued.	
This EN test report consists of the following parts:	
<input checked="" type="checkbox"/> IEC Test Report Number..... : CN24NYDV 001 and CN2406HM 001	
<input type="checkbox"/> EU Deviation Addendum..... :	
<input checked="" type="checkbox"/> OSM Decision Sheets..... See page 2	
Copyright © 2023, ETICS Brussels, Belgium. All rights reserved.	
This ECS document together with the test report is only valid if signed by an approved ENEC or CCA Testing Laboratory and accompanied by the associated ENEC Licence or CCA Notification of Test Results or other certificate, issued by a Certification Body member of ETICS.	



OD ECS 040-1
April 2023


Responsible CB



OSM Decision Sheet(s) taken into consideration:

Clause	Subject	OSM Decision Sheet No.
15	Varistor (VDR) and gas discharge tube (GDT)	DSH 2183
General	Insulation in SELV transformer	DSH 1069
9	Provision for earthing	DSH 2090A
18.2	Acceptance of Printed circuit boards (PCB)	DSH 2033A
10.4	No-load output voltage	DHS 2021

TEST REPORT IEC 62384 DC or AC supplied electronic controlgear for LED modules – Performance requirements	
Report Number.....	CN2406HM 001
Date of issue.....	See cover page
Total number of pages.....	10 pages
Name of Testing Laboratory preparing the Report	TÜV Rheinland (GuangDong) Co., Ltd.
Applicant's name	TIANCHANG FUAN ELECTRONIC CO., LTD.
Address.....	286, Renmin East Road, Renhe Town, Tianshang City, 239331 Anhui, P.R. China
Test specification: Standard..... : IEC 62384:2020 Test procedure..... : ENEC Non-standard test method..... : N/A	
TRF template used..... : IECEE OD-2020-F1:2022, Ed.1.5 Test Report Form No..... : IEC62384E Test Report Form(s) Originator ... : IMQ S.p.A. Master TRF..... : Dated 2022-12-02 Copyright © 2021 IEC System of Conformity Assessment Schemes for Electrotechnical Equipment and Components (IECEE System). All rights reserved. <small>This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.</small> This report is not valid as a CB Test Report unless signed by an approved IECEE Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.	
General disclaimer: The test results presented in this report relate only to the object tested. This report shall not be reproduced, except in full, without the written approval of the Issuing NCB. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.	

Test item description..... :	Constant Current LED Driver	
Trade Mark(s)..... :	 PAIRUI (PAIRUI)	
Manufacturer	Same as applicants	
Model/Type reference..... :	AAB045-C1050	
Ratings..... :	I/P: 220-240VAC, 50/60Hz, O/P: Max.44W SELV; Independent; Class II, IP20, ta:50°C, tc:75°C Other information see 'General production information'.	
Responsible Testing Laboratory (as applicable), testing procedure and testing location(s):		
<input checked="" type="checkbox"/>	Testing Laboratory:	TÜV Rheinland (GuangDong) Co., Ltd.
Testing location/ address..... :		No.199 Kezhu Road, GZ Science City, Guangzhou 510663, P.R.China
Tested by (name, function, signature) :		See cover page
Approved by (name, function, signature) :		See cover page
<input type="checkbox"/>	Testing procedure: CTF Stage 1:	
Testing location/ address..... :		N/A
Tested by (name, function, signature) :		N/A
Approved by (name, function, signature) :		N/A
<input type="checkbox"/>	Testing procedure: CTF Stage 2:	
Testing location/ address..... :		N/A
Tested by (name + signature)		N/A
Witnessed by (name, function, signature):		N/A
Approved by (name, function, signature) :		N/A
<input type="checkbox"/>	Testing procedure: CTF Stage 3:	
<input type="checkbox"/>	Testing procedure: CTF Stage 4:	
Testing location/ address..... :		N/A
Tested by (name, function, signature) :		N/A
Witnessed by (name, function, signature):		N/A
Approved by (name, function, signature) :		N/A
Supervised by (name, function, signature):		N/A

Summary of testing:**Tests performed (name of test, test clause and date test performed)**

Performance requirements has been evaluated according to IEC 62384:2020 and EN IEC 62384:2020. This report should be used in conjunction with CB report: CN24NYDV 001 issued by TÜV Rheinland (Shanghai) Co., Ltd.. All tests performed and passed.

Testing location: (CBTL, SPTL, CTF, Subcontractor)

TÜV Rheinland (GuangDong) Co., Ltd.
No.199 Kezhu Road, GZ Science City,
Guangzhou 510663, P.R.China

Summary of compliance with National Differences (List of countries addressed):

EU Group Differences

☒ The product fulfils the requirements of EN IEC 62384:2020 .

Use of uncertainty of measurement for decisions on conformity (decision rule) :

☒ No decision rule is specified by the IEC standard, when comparing the measurement result with the applicable limit according to the specification in that standard. The decisions on conformity are made without applying the measurement uncertainty ("simple acceptance" decision rule, previously known as "accuracy method").

☐ Other:... (to be specified, for example when required by the standard or client, or if national accreditation requirements apply)

Information on uncertainty of measurement:

The uncertainties of measurement are calculated by the laboratory based on application of criteria given by OD-5014 for test equipment and application of test methods, decision sheets and operational procedures of IECCE.

IEC Guide 115 provides guidance on the application of measurement uncertainty principles and applying the decision rule when reporting test results within IECCE scheme, noting that the reporting of the measurement uncertainty for measurements is not necessary unless required by the test standard or customer.

Calculations leading to the reported values are on file with the NCB and testing laboratory that conducted the testing.

Copy of marking plate:

PAIRUI
Constant Current LED Driver
LED控制装置 (恒流模式)

Model(型号): AAB045-C1050
PRI(输入): 220-240V ~ 0.28A MAX
50/60Hz λ:0.50-0.95
SEC(输出): 9-42VDC
Irated: 1050mA Max
Prated: 44W Max
Uout: 50VDC Max
ta: 50°C tc: 75°C

Irated	1	2	3	4
550mA	-	-	-	-
600mA	ON	-	-	-
650mA	-	ON	-	-
700mA	-	-	ON	-
750mA	-	-	-	ON
800mA	ON	-	-	ON
850mA	-	ON	-	ON
900mA	-	-	ON	ON
950mA	ON	-	ON	ON
1000mA	-	ON	ON	ON
1050mA	ON	ON	ON	ON

DA DA N L
PRI wire prep. 0.75-1.5mm
tc pushDIM
SELV
DALI 2
Made in China
TIANCHANG FUAN ELECTRONIC CO., LTD
Address: 286 Renmin East Road, Renhe Town,
Tianchang City, 239331 Anhui, P.R. China

Test item particulars : Constant Current LED Driver										
Classification of installation and use : SELV and Independent controlgear										
Supply Connection : Terminal										
Possible test case verdicts: - test case does not apply to the test object: N/A - test object does meet the requirement.....: P (Pass) - test object does not meet the requirement.....: F (Fail)										
Testing: Date of receipt of test item: 2023.12.28 Date (s) of performance of tests: 2023.12.28-2024.01.21										
General remarks:										
"(See Enclosure #)" refers to additional information appended to the report. "(See appended table)" refers to a table appended to the report. Throughout this report a <input checked="" type="checkbox"/> comma / <input type="checkbox"/> point is used as the decimal separator.										
Manufacturer's Declaration per sub-clause 4.2.5 of IEC 60730-2:										
The application for obtaining a CB Test Certificate includes more than one factory location and a declaration from the Manufacturer stating that the sample(s) submitted for evaluation is (are) representative of the products from each factory has been provided.....:						<input type="checkbox"/> Yes <input checked="" type="checkbox"/> Not applicable				
When differences exist; they shall be identified in the General product information section.										
Name and address of factory (ies): YIGUANG TECHNOLOGY(JIANGSU) CO.,LTD. Building 2, Yixing Photoelectric Industrial Park, No.10 xingli Road, Yixing Eco. Tech. Development Zone, 214200 JIANGSU, P.R.CHINA										
General product information and other remarks:										
Model list:										
Model	Input Voltage (VAC)	PF	Input Power	Input current (A)	Output voltage (VDC)	I _{rated} (mA)	P _{rated} (W)	U _{out} (VDC)	t _a (°C)	t _c (°C)
AAB045-C1050	220-240V	0.5-0.95	49.25W Max	0.28A Max	9-42VDC	550mA	44W max	50VDC	50	75
						600mA				
						650mA				
						700mA				
						750mA				
						800mA				
						850mA				
						900mA				
						950mA				
						1000mA				
1050mA										

5	CLASSIFICATION			P
5.1	Classification according to the load			P
	a) single value load control gear	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	N/A
	b) multiple value load control gear	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	P
5.2	Classification according to the output voltage			P
	a) control gear with stabilized output voltage.....	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	N/A
	b) control gear without stabilized output voltage:	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	P
5.3	Classification according to the output current			P
	a) control gear with stabilized output current.....	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	P
	b) control gear without stabilized output current:	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	N/A
6	MARKING			P
6.1	Mandatory marking			P
6.1.1	Circuit power factor.....	See marking plate		P
6.1.2	a) temperature range	-10°C~ta (Working ambient temperature provided in manual/catalogue.)		P
	b) stabilized output voltage			N/A
	c) stabilized output current			P
	d) operation with a mains supply dimmer			N/A
	e) operation mode			N/A
	f) rated minimum output power	equal to loading of Min. Uout*Min. Iout see “general product information” for details (remark: provided in manual/catalogue.)		P
6.2	Optional markings			P
	a) total circuit power.....	see “general product information” for details		P
	b) symbol for short-circuit proof type control gear			N/A
7	OUTPUT VOLTAGE AND CURRENT			P
7.1	Starting and connecting requirements			P
	Output within 110% of the rated value within 2 s			P
7.2	Voltage and current during operation			P
	For controlgear with stabilized / non-stabilized output voltage, the output voltage doesn't differ by more than ±10% of the rated voltage	See appended table		P

	For controlgear with stabilized / non-stabilized output current, the output current doesn't differ by more than $\pm 10\%$ of the rated current	See appended table	P
7.3	Capacitive load requirement		P
	LED module or any additional control unit not disturbing the controlgear overcurrent detection		P
	LED module or any additional control unit not disturbing the starting process of the controlgear		P
8	TOTAL CIRCUIT POWER		P
	Total circuit power $\leq 110\%$ of the value declared by the manufacturer	See appended table	P
9	CIRCUIT POWER FACTOR		P
	Circuit power factor \geq (marked value - 0,05)	See appended table	P
	Controlgear designed to provide constant luminous flux, provides the maximum output power		P
10	SUPPLY CURRENT		P
	Supply current doesn't differ by more than 10% from the marked value	See appended table	P
11	OPERATIONAL TESTS FOR ABNORMAL CONDITIONS		P
	Controlgear not damaged		—
	a) without LED module(s) inserted		P
	The LED module(s) operate(s) normally after test a)		P
	b) for reduced LED module resistance	Test under consideration	N/A
	c) for short-circuit proof control gear		N/A
	The controlgear operates normally after the tests and after restoration of a protecting device		N/A
12	ENDURANCE		P
12.1	a) Temperature cycling shock test (5 cycles):	Non-energised; $-10^{\circ}\text{C}(1\text{h})$; $t_{\text{c}}(1\text{h})$; 5 cycles	P
	b) Supply voltage switching test (200+800 cycles) ..:		P
	The controlgear operates an appropriate LED module(s) correctly for 15 min		P
12.2	The controlgear is operated at rated supply voltage and in ambient temperature which produces t_{c} , until a test period of 200 h has passed		P
	The controlgear operates an appropriate LED module(s) correctly for 15 min		P

7.2	TABLE: Voltage and current during operation				P
Supply voltage (a.c. or d.c.)	Rated output (voltage or current) U_{rated}	Measured output (voltage or current) U_{meas}	$(U_{meas} - U_{rated}) / U_{rated}$ (%)	Comments	
Min. load: 0,55A					
220VAC	9	8,99	-0,11	0,2m output cord	
240VAC	9	8,99	-0,11	0,2m output cord	
220VAC	9	8,99	-0,11	2m output cord	
240VAC	9	8,99	-0,11	2m output cord	
220VAC	42	42	0	0,2m output cord	
240VAC	42	42	0	0,2m output cord	
220VAC	42	42	0	2m output cord	
240VAC	42	42	0	2m output cord	
Max. load: 1,05A					
220VAC	9	9	0	0,2m output cord	
240VAC	9	9	0	0,2m output cord	
220VAC	9	9	0	2m output cord	
240VAC	9	9	0	2m output cord	
220VAC	42	42	0	0,2m output cord	
240VAC	42	42	0	0,2m output cord	
220VAC	42	42	0	2m output cord	
240VAC	42	42	0	2m output cord	

7.2	TABLE: Voltage and current during operation				P
Supply voltage (a.c. or d.c.)	Rated output (voltage or current) I_{rated}	Measured output (voltage or current) I_{meas}	$(I_{meas} - I_{rated}) / I_{rated}$ (%)	Comments	
Min. load: 9V					
92%*220VAC	0,55	0,55	0	0,2m output cord	
106%*240VAC	0,55	0,55	0	0,2m output cord	
92%*220VAC	0,55	0,55	0	2m output cord	
106%*240VAC	0,55	0,55	0	2m output cord	
Max. load: 42V					
92%*220VAC	1,05	1,04	-0,95	0,2m output cord	
106%*240VAC	1,05	1,04	-0,95	0,2m output cord	
92%*220VAC	1,05	1,04	-0,95	2m output cord	
106%*240VAC	1,05	1,04	-0,95	2m output cord	

8	TABLE: Total circuit power				P
Supply voltage (a.c. or d.c.)	Rated power P_{rated} (W)	Measured power P_{meas} (W)	P_{meas} / P_{rated} (%)	Comments	
220	49,25	49,33	100,2	0,2m output cord	
240	49,25	49,34	100,2	0,2m output cord	
220	49,25	49,33	100,2	2m output cord	
240	49,25	49,34	100,2	2m output cord	
Supplementary information:					

9	TABLE: Total Circuit power factor					P
Supply voltage (a.c.)	Output power (W)	Marked power factor λ_{mark}	Measured power factor λ_{meas}	$\lambda_{\text{meas}} - \lambda_{\text{mark}}$	Comments	
220	44	0,95	0,945	0,005	0,2m output cord	
240	44	0,95	0,936	0,014	0,2m output cord	
220	44	0,95	0,945	0,005	2m output cord	
240	44	0,95	0,936	0,014	2m output cord	
220	4,95	0,5	0,660	0,16	0,2m output cord	
240	4,95	0,5	0,642	0,142	0,2m output cord	
220	4,95	0,5	0,660	0,16	2m output cord	
240	4,95	0,5	0,642	0,142	2m output cord	

10	TABLE: Supply current				P
Supply voltage (a.c. or d.c.)	Rated current I_{rated} (A)	Measured current I_{meas} (A)	$(I_{\text{meas}} - I_{\text{rated}}) / I_{\text{rated}}$ (%)	Comments	
220	0,28	0,229	-18,21	0,2m output cord	
240	0,28	0,212	-24,29	0,2m output cord	
220	0,28	0,229	-18,21	2m output cord	
240	0,28	0,212	-24,29	2m output cord	
Supplementary information:					

-End of report-